



ADDENDUM NO. 3
WILSON PARK RENOVATION: RECREATION BUILDING AND
BASEBALL PARK IMPROVEMENTS
PROJECT NO. 2015-08
BID OPENING: JUNE 30, 2015
2:00 P.M.

ISSUED DATE: JUNE 25, 2015

The following revisions are hereby made to the above referenced project.

1. Revise Section 06 41 00 "Casework", Subsection 1.6 "Quality Assurance" as follows: Change "Architectural Woodwork Institute" to "Woodwork Institute".

Questions received to date with responses.

2. "What is the finish detail for the interceptor?"
Response: The interceptor is specified on the Plumbing drawings. The interceptor is surrounded by a metal cage as indicated on the drawings. The detail for the cage is attached in this addendum.
3. "What is the status of PG&E engineering review?"
Response: PG&E engineering design is underway.
4. "Is conduit required for new electrical work, or is MC cable allowed?"
Response: Conduit is required, as indicated on the electrical drawings.

Please indicate receipt of this addendum on the last page of the Proposal. Failure to do so may cause rejection of your bid.

APPROVED BY:


Timm Borden
Director of Public Works

Addendum No. 3

City of Cupertino

Wilson Park Renovation: Recreation Building and Baseball Park Improvements

